



LEGEND

- SANITARY SEWER — SS — SS —
- WATER — W — W —
- SANITARY SEWER MANHOLE ●
- FIRE HYDRANT ●
- BACKFLOW PREVENTER [Symbol]
- MEANS OF ACCESS TO STRUCTURES [Symbol]

GENERAL NOTES

1. PORT SAN LUIS HARBOR DISTRICT SHALL UPDATE ITS EMERGENCY ACTION PLAN TO INCLUDE EMERGENCY PREPAREDNESS PROTOCOLS FOR THE HARBOR TERRACE PROJECT.

FIRE FLOW REQUIREMENTS

| BUILDING | GSF (SF) | CONSTRUCTION TYPE | FIRE FLOW REQ (GPM) | FLOW DURATION (HRS) | HYDRANT SPACING (FT) |
|-------------------|----------|-------------------|---------------------|---------------------|----------------------|
| FUTURE HARBOR USE | 3,000 | II B | 1,500 GPM | 2 | 500 |
| COMMERCIAL | 16,000 | V B | 3,500 GPM | 3 | 400 |

PER 2010 CALIFORNIA FIRE CODE

FIRE SAFETY PLAN

LAND USE PERMIT SET

Scale 1"=60'

 North
 March 12 2014